



Annexure C

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Rc.No. 204 / SHP / DM&HO / Medchal / 2026 - 27.

Dated: 03 / 07 / 2026.

It is certified that an inspection team headed by Y. Vijay Kumar, Health Inspector, Medchal Malkajgiri District, from DM&HO Office (Health Department) and Directorate of I.P.M.P.H. Labs, Hyderabad - certified Accredited Laboratory have inspected M/s **Mallareddy School**, Located at Sy.No: 1101, Medchal Village & Mandal, Medchal - Malkajgiri District on 02.07.2026 and on the basis of Water Test Report (Attached) bearing Sample ID.No. 7717, 7718, dated: 22.06.2026 from Directorate of I.P.M.P.H. Labs, Hyderabad certified that the Mallareddy School has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

This Certificate is valid for a period of One year from date of issue.

Signature with Seal. *[Signature]* Dist. Medical & Health officer

Name: Dr. C. Uma Gowri,

Designation: District Medical & Health Officer
Medchal Malkajgiri District

To
The Principal,
Mallareddy School,
Sy.No: 1101,
Medchal Village & Mandal,
Medchal Malkajgiri District.

P. Smithya

MANAGER
MALLA REDDY SCHOOL
Sy. No. 1101, Medchal Village,
Medchal Mandal,
Medchal-Malkajgiri Dist, Telangana

Swathy.v.
PRINCIPAL
MALLA REDDY SCHOOL
Sy. No. 1101, Medchal Village,
Medchal Mandal,
Medchal-Malkajgiri Dist, Telangana

GOVERNMENT OF TELANGANA

DEPARTMENT OF WATER AND WASTE WATER EXAMINATION

Directorate of I.P.M,P.H.Labs, Food (H) Administration, Narayanaguda, Hyderabad – 29.

REPORT OF PHYSICO CHEMICAL ANALYSIS OF WATER

REPORT OF PHYSICO-CHEMICAL ANALYSIS OF WATER					
Sample From		K.Syam Sai,		Collected by	Party
Address		Mallareddy School Sy.No:1101, Medchal (V)& (m)		Collected on	22-06-2026
District		Medchal-Malkajgiri		Received on	22-06-2026
State		Telangana		Sample volume	2 ltr
Source profile		Borewell / R.O water		Sample ID	7717 / 7718
S.No	Parameter	Source / Sample ID		Drinking Water -Specification As per IS 10500 :2012	
		Direct Borewell water collected from above address / 7717	Direct R.O water collected from above address / 7718	Requirement (Acceptable)	Permissible limit in the absence of alternative source
Physical parameters					
1	colour(Hazen),max	<5	<5	5	15
2	Turbidity (NTU),max	0.47	0.56	1	5
3	Odour	Un-Objectionable	Un-Objectionable	UnObjectionable	UnObjectionable
4	Taste	Agreeable	Agreeable	Agreeable	Agreeable
5	p ^H	6.5	6.6	6.5 - 8.5	No relaxation
6	Electrical Conductivity at 25°C (Micro Mhos/cm)	154	180		
7	TDS(mg/L),max	101	117	500	2000
Chemical parameters (mg/L)					
1	Alkalinity(as CaCO3),phenolphthalein ,max	Nil	Nil	...	...
2	Total alkalinity (as CaCO3) ,max	15	16	200	600
3	Total hardness (as CaCO3),max	39	49	200	600
4	Calcium hardness (as CaCO3),max	20	25		
5	Magnesium hardness (as CaCO3),max	19	24		
6	Calcium (as Ca),max	8.0	10	75	200
7	Magnesium (as Mg),max	4.6	5.8	30	100
8	Ammonical Nitrogen,max	Nil	Nil		
9	Nitrite(as N),max	Nil	Nil		
10	Nitrate(as N),max	Nil	Nil	45	No relaxation
11	Sulphate (as SO4),max	Nil	2	200	400
12	Chloride(as Cl),max	25	27	250	1000
13	Fluoride(as F),max	0.02	0.09	1.0	1.5
14	Iron (as Fe),max	Nil	Nil	0.3	No relaxation

Remarks: The above samples are physico chemically satisfactory.

The sample was submitted by the party and was not collected by laboratory personnel.

Hence, the results pertain only to the sample as received. The laboratory does not take responsibility for the source, representativeness, or integrity of the sample.

MALLAREDDY SCHOOL
Sy. No. 1101, Medchal Village,
Medchal Mandal,
Medchal-Malkajgiri Dist, Telangana

MALLAREDDY SCHOOL
Sy. No. 1101, Medchal Village,
Medchal Mandal,
Medchal-Malkajgiri Dist, Telangana

Signature